

Energy Wastage and Recovery Options in Buildings



WEBINAR SAARC ENERGY CENTRE

23/06/2020

Dr. Mohammad Adil

Deputy Director

www.**CIBEA**.com.pk



Today!

- ❑ Introduction
- ❑ Building Energy Wastage
- ❑ CIBEA's study on Building Energy Wastage in Peshawar City.
- ❑ Use of Building Information Modelling in Energy wastage control.

Our team at CIBEA.com.pk



Dr. M. A. Irfan Mufti
Director CIBEA



Dr. Mohammad Adil
Deputy Director CIBEA



Engr. Faizullah
Energy Engineer (Electrical)



Engr. Zaeem Ahmed
Energy Engineer (Thermal)



Engr. Rizwan
Energy Engineer (Thermal)



Engr. Adeed Khan
Building Performance Analyst



Owais Javed
Web Developer



Engr. Iram Shahzadi
Energy Engineer



Ayesha Malik
Digital Marketing



Engr. M. Amar Zaib Khan
Trainee Engineer



Engr. Inam Ullah
Trainee Engineer

Building Team of CIBEA.com.pk



Dr. Mohammad Adil
Deputy Director CIBEA
Asst. Prof. UET Peshawar



Engr. M. Amar Zaib Khan
Trainee Engineer



Engr. Inam Ullah
Trainee Engineer



Engr. Adeed Khan
Building Performance Analyst


Equipment at CIBEA



11. Blowerdoor



1. Energy Analyzer (KW, KVA, PF, Harmonics)



2. Thermal Imager Baltech TR-0120



3. Anemometer EXTECHAN 340



4. Anemometer Dwyer VT-200



5. Video Boroscope EXTECH BR 250-4



6. Laser Range Finder



7. Moisture Humidity Meter EXTECH MO 295



8. IR Thermometer Fluke 572-2




9. Laser Distance Meter Fluke 419 D



10. Flue Gas Analyzer Testo 320

Sector-wise Energy Consumption in Pakistan



Building Energy Wastage

In Pakistan,


73% of
population has
access to
electricity.

25% of
electricity is
lost
technically
and by theft
etc.

??% of energy is
wasted at
consumer end.




Energy Saving with Energy Efficient Equipment




Energy Consumption in Buildings

Residential Building Share



Commercial Building Share



Question remains!

- **How much energy is wasted in/by building (design)?**



Consuming this wasted energy will reduce demand on providers.

Blowerdoor Test



Blowerdoor Test



Team CIBEA setting the blowerdoor equipment




Taking depressurization readings

Blowerdoor Test Commercial Building A

Rooms Layout


Room Legend

- ACAD 101
- ACAD 102
- ACAD 103
- ACAD 104
- ACAD 105
- ACAD 106
- ACAD 107
- ACAD 108
- BATH
- CORRIDOR
- office
- STAIRS



Room Legend

- ACAD 201
- ACAD 202
- ACAD 203
- ACAD 204
- ACAD 205
- ACAD 206
- ACAD 207
- ACAD 208
- BATH
- CORRIDOR
- office
- STAIRS



Blowerdoor Test Commercial Building A

Room #	Airflow at 50 pa,cfm @50	Air changes at 50 pa, n50 (/h at 50 pa)	Effective leakage area at 4 pa (cm ²)	Equivalent leakage area at 10 pa(cm ²)	LEED permeability at 4 pa (cm ² /100m ²)	Volume (m ³)	Floor area (m ²)	Enclosure area (m ²)
ACAD 101*	1040.6	13.98	396.2	726	247	126.5	41.4	160.4
ACAD 102	875.1	11.94	319.5	594.5	199.1	126.5	41.4	160.4
ACAD 103	1040.6	13.98	396.2	726	247	126.5	41.4	160.4
ACAD 104*	1267.5	17.02	512	918.5	319	126.5	41.4	160.4
ACAD 105	998.79	10.19	321.7	626.5	158.4	166.6	56.1	203.1
ACAD 106*	1157	11.8	364.9	716.1	179.7	166.6	56.1	203.1
ACAD 107	1171.5	11.78	468.5	843.5	230.5	166.6	56.1	203.1
ACAD 108	1157	11.8	364.9	716.1	179.7	166.6	56.1	203.1
ACAD 201*	1116.7	15	444.1	801.2	276.8	126.5	41.4	160.4
ACAD 202*	1040.6	13.98	396.2	726	247	126.5	41.4	160.4
ACAD 203	1116.7	15	444.1	801.2	276.8	126.5	41.4	160.4
ACAD 204	1267.5	17.02	512	918.5	319	126.5	41.4	160.4
ACAD 205*	998.79	10.19	321.7	626.5	158.4	166.6	56.1	203.1
ACAD 206	1344.3	13.71	349.7	735.9	172.2	166.6	56.1	203.1
ACAD 207*	1171.5	11.78	468.5	843.5	230.5	166.6	56.1	203.1
ACAD 208	1200.1	12.24	488.5	873.9	240.5	166.6	56.1	203.1



* Values are not measured but are taken from similar room's data

FROM BLOWERDOOR TEST

- **ACH @ 50 PASCAL = 13.2**
- LBL N Factor = 9.71
- n ACH = 1.36



BIM Model of Commercial Building A



Blowerdoor Test Commercial Building A

Comparison of heating and cooling load for 1.36 and 0.5 ACH

HEATING AND COOLING LOAD FOR 1.36 ACH	
Peak Cooling Total Load (Btu/h)	413,147.4
Peak Cooling Airflow (CFM)	12,290
Peak Heating Load (Btu/h)	111,755.3
Peak Heating Airflow (CFM)	2,361

HEATING AND COOLING LOAD FOR 0.52 ACH	
Peak Cooling Total Load (Btu/h)	366,606.1
Peak Cooling Airflow (CFM)	12,222
Peak Heating Load (Btu/h)	75,991.4
Peak Heating Airflow (CFM)	2,158

Average ACH @ 50 pa = 13.21
 Which when Converted to Natural ACH becomes 1.36


Similarly,
 Natural ACH = 0.52
 Which when Converted to ACH @ 50 pa becomes 5 ACH

If we make the rooms air tight and reduce ACH @ 50 pa from 13.21 to 5 ACH the peak heating and cooling loads reduces.

Difference in peak Cooling load = **46541.3 (btu/h)**

Difference in peak Heating load = **35763.9 (btu/h)**

Blowerdoor Test Residential Building B




FROM BLOWERDOOR TEST

- **ACH @ 50 PASCAL = 34**
- LBL N Factor = 14.28
- n ACH = 2.38



BIM Model in Revit and Energy Analysis



Blowerdoor Test Residential Building A

Comparison of heating and cooling load for 2.38 and 0.5 ACH

HEATING AND COOLING LOAD FOR 2.38 ACH	
Peak Cooling Total Load (Btu/h)	18,330.4
Peak Cooling Airflow (CFM)	452
Peak Heating Load (Btu/h)	15,855.7
Peak Heating Airflow (CFM)	483

HEATING AND COOLING LOAD FOR 0.52 ACH	
Peak Cooling Total Load (Btu/h)	13,396.2
Peak Cooling Airflow (CFM)	452
Peak Heating Load (Btu/h)	10,067.6
Peak Heating Airflow (CFM)	454

ACH @ 50 pa = 34 which when Converted to Natural ACH becomes 2.38

Similarly,
 Natural ACH = 0.52
 Which when Converted to ACH @ 50 pa becomes 7 ACH

If we make the rooms airtight and reduce ACH @ 50 pa from 34 to 5 ACH the peak heating and cooling loads reduces.

Difference in peak Cooling load = **4934.2 (btu/h)**

Difference in peak Heating load = **3328.6 (btu/h)**

Finally

RESIDENTIAL BUILDINGS

- The reduction in cooling load due to infiltration control is around **25 %** of the total cooling load.
- And the reduction in heating load is around **21%** of total heating load.

COMMERCIAL BUILDINGS

- The reduction in cooling load due to infiltration control is around **12 %** of the total cooling load.
- And the reduction in heating load is around **32%** of total heating load.

BIM+ BLOOWER DOOR Audit

Is a possible way of reducing **12-32%** of energy wastage *in heating and cooling*

or

7-17% *reduction of the total energy demand* in all sectors combined.

THANK YOU



Any Questions

www.**CIBEA**.com.pk